

January 23, 2009

VAN GOETHEM SEPTIC SYSTEMS, INC.  
CONCRETE DEPT.  
LONNY VAN GOETHEM  
EAST 3055 COUNTY HWY J  
KEWAUNEE WI 54216

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: VAN GOETHEM SEPTIC SYSTEMS, INC.  
Product Name: SEPTIC/SEPTIC/SEPTIC, SEPTIC/SEPTIC/PUMP OR HOLDING  
Model Number(s): 990/290/775 (3-compartment)  
(42" L.L. , 23.6/7.0/18.5 GAL/IN., 48" MAX. DEPTH OF BURY, 990 G.P.D. WHEN USED  
AS A SEPTIC/SEPTIC/SEPTIC OR 617 G.P.D. WHEN USED AS A  
SEPTIC/SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR  
RESIDENTIAL WASTEWATER)  
Product File No: 20090021

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of MARCH 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Four inch discharge opening in riser.
  - Bottom and side pipe openings for siphon, pump and holding tanks.
  - Six inch inlet and outlet openings.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
  - Dual inlets at end of tank with one access opening above both inlets.
  - Dual inlets at end of tank with one access opening above each inlet.

January 23, 2009

- Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- A concrete panel slid into a groove in the sidewalls to create a 2 compartment septic tank to aid in the settling out of solids in the effluent.
- 24" riser by EZ Set Tank Company

This approval supersedes the approval issued on 1/21/2007 under product file number 20070359. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070359.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov